

Attestation of Conformity

No. N8A 075834 0841 Rev. 00

Holder of Attestation: **Shenzhen MEGMEET Electrical Co., Ltd.**

5th Floor, Tower A, B,C501-C503,D,E
Unis Inforport, No.13 Langshan Road
North Section, Hi-Tech Industrial Park
Nanshan District
518057 Shenzhen
PEOPLE'S REPUBLIC OF CHINA

Product: **Programmable Controller**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 68240260691701

Date, 2026-08-12



(Alex Kong)

Attestation of Conformity

No. N8A 075834 0841 Rev. 00

Model(s): MU200-1210BTA, MU200-1210BRA, MU200-1616BTA, MU200-1616BRA, MU200-2424BTA, MU200-2424BRA, MU200-3232BTA, MU200-3232BRA, MU200-4040BTA, MU200-4040BRA, MU300-0808BTA, MU300-1210BTA, MU300-1210BRA, MU300-2424BTA, MU200-4DA, MU200-4AD, MU200-4PT, MU200-4AM, MU200-8TC, MU200-8AD, MU200-0808ERN, MU200-0808ETN, MU200-0016ERN, MU200-0016ETN, MU200-1600ENN

Brand: MEGMEET



Parameters:

Ratings: See below table for details

Remarks:

- When installing the equipment, all requirements of the mentioned standard must be fulfilled.
- Open-type equipment, suitable enclosure should be provided in end system.
- The maximum operating temperature is 50°C.
- Clearance was evaluated for operating altitude up to 2000m above sea level.

Tested according to: EN 61010-1:2010/A1:2019
EN IEC 61010-2-201:2018

Attestation of Conformity

No. N8A 075834 0841 Rev. 00